

## Drikkevannsprøver Lo vannverk (overflatevann, behandlet) 2020

## Rapportering Altinn

Analyse	Enhet	Tiltaksgrense	13.1.	10.2.	2.3.	27.4.	25.5.	29.6.	10.8.	31.8.	7.9.	5.10.	2.11.	30.11.	Median	Gj.s	Min	Max
			Hybelhus	Dagbygg	Dagbygg	Stasjon	Hybel	Hybelhus	Dagbygg	Dagbygg	Dagbygg	Dagbygg	Dagbygg	Hybelhus				
Kimtall 22°C	Antall/ml	< 100	3	300	2	3	1260	6	2	10	19	19	ikke påvist	4	6,0	148,0	2,0	1260,0
Koliforme bakterier	Antall/100 ml	< 1	0	0	0	0	0	0	0	0	0	0	0	0	0,0	0,0	0,0	0,0
E.coli	Antall/100 ml	< 1	0	0	0	0	0	0	0	0	0	0	0	0	0,0	0,0	0,0	0,0
I. Enterokokker	Antall/100 ml	< 1	0	0	0	0	0	0	0	0	0	0	0	0	0,0	0,0	0,0	0,0
pH	Surhetsgrad	ok innenfor 6,5 - 9,5	7	6,6	6,7	6,7	6,8	6,9	6,9	6,9	6,6	6,7	6,7	6,6	6,9	6,8	6,6	7,0
Farge	mg/l	< 20	6	8	6	20	11	4	4	3	3	6	7	9	4,0	7,3	3,0	20,0
Konduktivitet	mS/m ved 20°C	< 250	4,3	3,3	4,1	3,8	3,4	2	1,6	2,1	1,9	1,7	2,5	2,9	2,0	2,8	1,6	4,3
Turbiditet	FTU	< 1	0,17	0,33	0,4	0,27	0,29	0,96	0,29	0,36	0,19	0,24	0,4	0,6	1,0	0,4	0,2	1,0
<b>Skal testes etter rengjøring/større vedlikehold:</b>																		
Ammonium	mg/l	< 0,5													#NUM!	#DIV/0!	0	0
Jern	mg/l	< 0,2													#NUM!	#DIV/0!	0	0
Nitritt	mg/l	< 0,5													#NUM!	#DIV/0!	0	0
Aluminium	mg/l	< 0,2													#NUM!	#DIV/0!	0	0

