

Drikkevannsprøver Naddvik vannverk 2020
Rapportering Altinn

Analyse	Enhet	Tiltaksgrense	13.1.	10.2.	2.3.	27.4.	25.5.	29.6.	20.7.	25.8.	7.9.	5.10.	2.11.	30.11.	Median	Gj.s	Min	Max	
			Sigurd.S	Sigurd.S	Sigurd.S	Sigurd.S	Sigurd.S	Dagbygg	Sigurd.S	Naddvik	Naddvik	Sigurd.S	Naddvik	Sigurd.S					
Kimtall 22°C	Antall/ml	< 100	39	31	16	5	41	10	4	5	12		12	35	10,0	19,1	4,0	41,0	
Koliforme bakterier	Antall/100 ml	< 1	0	0	0	0	0	0	0	0	0		0	0	0,0	0,0	0,0	0,0	
E.coli	Antall/100 ml	< 1	0	0	0	0	0	0	0	0	0		0	0	0,0	0,0	0,0	0,0	
I. Enterokokker	Antall/100 ml	< 1	0	0	0	0	1	0	0	0	0		0	0	0,0	0,1	0,0	1,0	
pH	Surhetsgrad	ok innenfor 6,5 - 9,5	7,7	7,7	7,5	7,6	7,3	10,6	7,6	7,7	7,8		7,5	7,7	10,6	7,9	7,3	10,6	
Farge	mg/l	< 20	3	3	3	3	3	3	3	3	3		3	3	3,0	3,0	3,0	3,0	
Konduktivitet	mS/m ved 20°C	< 250	8,1	8,4	8,1	8,4	8	14,6	7,6	7,8	7,8		7,8	8,2	14,6	8,6	7,6	14,6	
Turbiditet	FTU	< 1	0,1	0,21	0,2	0,21	0,19	0,62	0,2	0,23	0,31		0,32	0,33	0,6	0,3	0,1	0,6	
Skal testes etter rengjøring/større vedlikehold:																			
Ammonium	mg/l	< 0,5													#NUM!	#DIV/0!	0	0	
Jern	mg/l	< 0,2													#NUM!	#DIV/0!	0	0	
Nitritt	mg/l	< 0,5													#NUM!	#DIV/0!	0	0	
Aluminium	mg/l	< 0,2													#NUM!	#DIV/0!	0	0	

