

Drikkevannsprøver Lo vannverk (overflatevann, behandlet) 2021

Rapportering Altinn

Analyse	Enhet	Tiltaksgrense	18.1.	15.2.	15.3.	19.4.	18.5.	14.6.	19.7.	16.8.	13.9.	11.10.	8.11.	6.12.	Median	Gj.s	Min	Max
			Dagbygg	Hybelhus	Dagbygg	Hybelhus	Dagbygg	Dagbygg	Dagbygg	Dagbygg	Dagbygg	Dagbygg	Dagbygg	Dagbygg				
Kimtall 22°C	Antall/ml	< 100		2	2	7	72								4,5	20,8	2,0	72,0
Koliforme bakterier	Antall/100 ml	< 1		0	0	0	0								0,0	0,0	0,0	0,0
E.coli	Antall/100 ml	< 1		0	0	0	0								0,0	0,0	0,0	0,0
I. Enterokokker	Antall/100 ml	< 1		0	0	0	2								0,0	0,5	0,0	2,0
pH	Surhetsgrad	ok innenfor 6,5 - 9,5		7,1	6,9	7,1	6,7								7,0	7,0	6,7	7,1
Farge	mg/l	< 20		3	4	3	12								3,5	5,5	3,0	12,0
Konduktivitet	mS/m ved 20°C	< 250		3,7	3,6	4	3,1								3,7	3,6	3,1	4,0
Turbiditet	FTU	< 1		0,41	0,23	0,36	0,26								0,3	0,3	0,2	0,4
Skal testes etter rengjøring/større vedlikehold:																		
Ammonium	mg/l	< 0,5													#NUM!	#DIV/0!	0	0
Jern	mg/l	< 0,2													#NUM!	#DIV/0!	0	0
Nitritt	mg/l	< 0,5													#NUM!	#DIV/0!	0	0
Aluminium	mg/l	< 0,2													#NUM!	#DIV/0!	0	0

