

Drikkevannsprøver Naddvik vannverk 2021

Rapportering Altinn

Analyse	Enhet	Tiltaksgrense	11.1.	8.2.	8.3.	6.4.	3.5.	03.06.	19.7.	2.8.	30.8.	4.10.	1.11.	29.11.	Median	Gj.s	Min	Max
			Sigurd.S	Sigurd.S	Sigurd.S	Naddvik	Naddvik	Sigurd.S	Sigurd.S	Sigurd.S	Sigurd.S	Sigurd.S	Sigurd.S	Sigurd.S				
Kimtall 22°C	Antall/ml	< 100	5	6	2	15	ikke påvist	4							5,0	6,4	2,0	15,0
Koliforme bakterier	Antall/100 ml	< 1	0	0	0	0	0	0							0,0	0,0	0,0	0,0
E.coli	Antall/100 ml	< 1	0	0	0	0	0	0							0,0	0,0	0,0	0,0
I. Enterokokker	Antall/100 ml	< 1	0	0	0	0	0	0							0,0	0,0	0,0	0,0
pH	Surhetsgrad	ok innenfor 6,5 - 9,5	7,8	7,8	7,8	7,5	7,8	7,4							7,8	7,7	7,4	7,8
Farge	mg/l	< 20	3	3	3	3	3	3							3,0	3,0	3,0	3,0
Konduktivitet	mS/m ved 20°C	< 250	10,2	10,3	8,1	8	9,8	7,8							9,0	9,0	7,8	10,3
Turbiditet	FTU	< 1	0,22	0,25	0,15	0,18	0,12	0,16							0,2	0,2	0,1	0,3
Skal testes etter rengjøring/større vedlikehold:																		
Ammonium	mg/l	< 0,5													#NUM!	#DIV/0!	0	0
Jern	mg/l	< 0,2													#NUM!	#DIV/0!	0	0
Nitritt	mg/l	< 0,5													#NUM!	#DIV/0!	0	0
Aluminium	mg/l	< 0,2													#NUM!	#DIV/0!	0	0

