

Ren bærekraft

Analyse	Enhet	Tiltaksgrense	16.1.	13.2.	13.03.	17.04.								Median	Gj.s	Min	Max
			Dagbygg	Hybelhus	Dagbygg	Dagbygg	Dagbygg	Dagbygg	Hybelhus	Dagbygg	Dagbygg	Dagbygg	Dagbygg				
Kimtall 22°C	Antall/ml	< 100	3	1	3	154								3,0	40,3	1,0	154,0
Koliforme bakterier	Antall/100 ml	< 1	0	0	0	1								0,0	0,3	0,0	1,0
E.coli	Antall/100 ml	< 1	0	0	0	0								0,0	0,0	0,0	0,0
I. Enterokokker	Antall/100 ml	< 1	0	0	0	0								0,0	0,0	0,0	0,0
Lukt	Poeng	Akseptabelt for abonnentene	0	0	0	0								0,0	0,0	0,0	0,0
Smak	Poeng	Akseptabelt for abonnentene	0	0	0	0								0,0	0,0	0,0	0,0
pH	Surhetsgrad	ok innenfor 6,5 - 9,5	6,6	6,9	6,6	6,7								6,7	6,7	6,6	6,9
Farge	mg/l	< 20	3	4	3	8								3,5	4,5	3,0	8,0
Konduktivitet/ledningsevne	mS/m ved 20°C	< 250	3,5	13,2	4,5	6,7								5,6	7,0	3,5	13,2
Turbiditet	FTU	< 1	0,47	0,56	0,22	0,4								0,4	0,4	0,2	0,6
Skal testes etter rengjøring/større vedlikehold:																	
Ammonium	mg/l	< 0,5												#NUM!	#DIV/0!	0	0
Jern	mg/l	< 0,2												#NUM!	#DIV/0!	0	0
Nitritt	mg/l	< 0,5												#NUM!	#DIV/0!	0	0
Aluminium	mg/l	< 0,2												#NUM!	#DIV/0!	0	0

