

Analyse	Enhet	Tiltaksgrense	16.1.	13.2.	13.03.	17.04.	22.5.	12.6.	17.07.	14.8.						Median	G.j.s	Min	Max
			Dagbygg	Hybelhus	Dagbygg	Dagbygg	Dagbygg	Dagbygg	Hybelhus	Dagbygg	Dagbygg	Dagbygg	Dagbygg	Dagbygg	Dagbygg	Dagbygg	Dagbygg		
Kimtall 22°C	Antall/ml	< 100	3	1	3	154	10	7	1	3						3,0	22,8	1,0	154,0
Koliforme bakterier	Antall/100 ml	< 1	0	0	0	1	0	0	0	0						0,0	0,1	0,0	1,0
E.coli	Antall/100 ml	< 1	0	0	0	0	0	0	0	0						0,0	0,0	0,0	0,0
I. Enterokokker	Antall/100 ml	< 1	0	0	0	0	0	0	0	0						0,0	0,0	0,0	0,0
Lukt	Poeng	Akseptabelt for abonentene	0	0	0	0	0	0	0	0						0,0	0,0	0,0	0,0
Smak	Poeng	Akseptabelt for abonentene	0	0	0	0	0	0	0	0						0,0	0,0	0,0	0,0
pH	Surhetsgrad	ok innenfor 6,5 - 9,5	6,6	6,9	6,6	6,7	6,6	6,8	6,6	6,7						6,7	6,7	6,6	6,9
Farge	mg/l	< 20	3	4	3	8	15	9	5	14						6,5	7,6	3,0	15,0
Konduktivitet/lednings	mS/m ved 20°C	< 250	3,5	13,2	4,5	6,7	3,4	1,8	1,7	2,6						3,5	4,7	1,7	13,2
Turbiditet	FTU	< 1	0,47	0,56	0,22	0,4	0,7	0,48	0,52	1,5						0,5	0,6	0,2	1,5

Skal testes etter rengjøring/større vedlikehold:

Ammonium	mg/l	< 0,5														#NUM!	#DIV/0!	0	0
Jern	mg/l	< 0,2														#NUM!	#DIV/0!	0	0
Nitritt	mg/l	< 0,5														#NUM!	#DIV/0!	0	0
Aluminium	mg/l	< 0,2														#NUM!	#DIV/0!	0	0

